TYPE OF LINE USED

- 1" TYPE "K" COPPER PIPE
- 3/4" TYPE "K" COPPER PIPE
- JOHN MANVILLE ASBESTOS CEMENT WATER MAIN-CLASS 150 6100' ±

CERTIFICATION

REVISIONS

NO.	DATE

BEECHWOOD MANOR
WATER LINES

quible and associates, incorporated
CONSULTING ENGINEERS CHASE CITY, VIRGINIA

COMMISSION NO.	
DESIGNED BY	
DRAWN BY	
CHECKED BY	
ISSUE DATE	

SHEET NO. 1 OF 1