NOTE: CONTRACTOR SHALL DETERMINE IF ANY SANITARY LATERALS WERE INSTALLED ON THE EXISTING ~~SANITARY~~ SEWER LINE. IF LATERALS ARE FOUND TO EXIST, THEN THEY SHALL BE USED WHERE EVER POSSIBLE. ANY LATERALS THAT ARE NOT USED WILL NEED TO BE DISCONNECTED AND PROPERLY PLUGGED WITH CONCRETE.

NOTE: CONTRACTOR SHALL COORDINATE WITH THE BANK OF MCKENNY, THE COUNTY AND ANY OTHER AFFECTED PARCEL PRIOR TO SHUTTING OFF THE WATER. A MINIMUM 48 HOURS NOTICE SHALL BE PROVIDED.

COMMONWEALTH OF VIRGINIA
DERRICK A. JOHNSON
Lic. No. 24761
9-30-09
PROFESSIONAL ENGINEER

THIS DRAWING PREPARED AT THE
TRI-CITIES OFFICE
4260 Crossings Blvd | Prince George, VA 23875
TEL 804.458.8685 FAX 804.751.0798 www.timmons.com

YOUR VISION ACHIEVED THROUGH OURS.

Site Development | Residential | Infrastructure | Technology

DATE	REVISION DESCRIPTION
01-15-09	COUNTY COMMENTS
03-02-09	COUNTY COMMENTS
05-18-09	OWNER REVISIONS
09-30-09	COUNTY COMMENTS

DATE	02 JULY 2008
DRAWN BY	K.HALPAUS
DESIGNED BY	K.HALPAUS
CHECKED BY	D.JOHNSON
SCALE	1"=30'

TIMMONS GROUP

INDEPENDENCE PLACE APARTMENTS

BLAND DISTRICT - PRINCE GEORGE COUNTY - VIRGINIA

UTILITY LAYOUT

JOB NO. 25056

SHEET NO. 6

These plans and associated documents are the exclusive property of TIMMONS GROUP and may not be reproduced in whole or in part and shall not be used for any purpose whatsoever, inclusive, but not limited to construction, bidding, and/or construction staking without the express written consent of TIMMONS GROUP.